

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
COLORADO RIVER BASIN REGION

ORDER NO. 80-5

WASTE DISCHARGE REQUIREMENTS
FOR
LAKE CHUCKWALLA - MOBILE HOME PARK
Bermuda Dunes - Riverside County

The California Regional Water Quality Control Board, Colorado River Basin Region finds that:

1. Creative Financial Corporation (hereinafter also referred to as the discharger), P.O. Box 2092, Palm Desert, CA 92260, submitted a Report of Waste Discharge, dated November 6, 1979.
2. The discharger proposes to discharge a maximum of 68,000 gallons per day of domestic sewage from a mobile home park designed to have 268 spaces and a recreation building. Wastewater would be disposed of by no means of septic tank/seepage pit disposal systems to be located in the SE $\frac{1}{4}$ of Section 31, T4S, R7E, SBB SBB&M, and in the NE $\frac{1}{4}$ of Section 6, T5S, R7E, SBB&M.
3. The discharger is reserving areas of sufficient size for possible future 100 percent replacement of the seepage pits.
4. There are no domestic wells within 200 feet of the proposed discharge facilities described in Findings No. 2 and 3 (above).

The discharger states that wastewater from a swimming pool would be periodically discharged into a separate seepage pit.

6. The Water Quality Control Plan for the West Colorado River Basin was adopted by the Board on April 10, 1975. The Basin Plan contains water quality objectives for the Coachella Hydrologic Subunit.
7. The beneficial uses of the groundwater of the Coachella Hydrologic Subunit are:
 - a. Municipal supply
 - b. Industrial supply
 - c. Agricultural supply

*Received
by 85-112
11/20/85*

8. The Board has notified the discharger and interested agencies and persons of its intent to prescribe waste discharge requirements for the proposed discharge.
9. The Board in a public meeting heard and considered all comments pertaining to the proposed discharge.
10. The Riverside County Planning Department has approved Negative Declaration No. EA 995 (filing date March 7, 1974) for this proposed park. The Regional Board has reviewed this Negative Declaration. The below waste discharge requirements are designed to assure against any significant adverse effects on water quality.

IT IS HEREBY ORDERED, the discharger shall comply with the following:

A. Discharge Specifications

1. Neither the treatment nor the discharge of wastewater shall create a pollution or a nuisance as defined in Division 7 of the California Water Code.
2. No wastewater other than domestic sewage shall be discharged at this location.
3. Wastewater discharged subsurface shall be retained underground with no surfacing.
4. Adequate measures shall be taken to assure that flood or surface drainage waters do not erode or otherwise render portions of the discharge facilities inoperable.
5. Septic tank cleanings shall be discharged only by a duly authorized service.
6. Swimming pool wastewater shall not be discharged into a sewage disposal system.

B. Provisions

1. This Order will be rescinded if the Board determines that the County Health Department mandates that the discharger hook up to a municipal sewerage system.
2. Sufficient land area shall be reserved for possible future 100 percent replacement of the seepage pits, until such time as this park is connected to a municipal sewerage system.
3. Upon request from this Board's Executive Officer, the discharger shall furnish technical and/or monitoring reports on the treatment and discharge of wastes.


4. The subsurface sewerage system should be designed and constructed to facilitate possible connection to the Coachella Valley Water District sewerage system when available.
5. Prior to any modifications in this facility which would result in material change in the quality or quantity of wastewater discharged, or any material change in location of discharge, the discharger shall report in writing to the Regional Board.
6. Prior to any change of ownership of this mobile home park, the discharger shall:
 - a. Specify as a condition of transfer that the area specified in Provision B.2. (above) remain servient to the development, for the purpose of providing additional subsurface sewage disposal capacity, until such time as this development is connected to a municipal sewerage system.
 - b. Notify the succeeding owner, in writing, of the existence of this Order, and forward a copy of said correspondence to the Regional Board.

I, Arthur Swajian, Executive Officer, do hereby certify the foregoing is a full, true, and correct copy of an Order adopted by the California Regional Water Quality Control Board, Colorado River Basin Region, on January 23, 1980.



Executive Officer

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD - 7



SITE MAP

LAKE CHUCKWALLA - MOBILE HOME PARK
 Bermuda Dunes - Riverside County
 SE 1/4 of Section 31, T4S, R7E, SBB&M
 and NE 1/4 of Section 6, T5S, R7E, SBB&M
 USGS Thousand Palms and Palm Desert 15 min.
 Topographic Maps