

**CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
COLORADO RIVER BASIN REGION**

ORDER NO. 85-69

**WASTE DISCHARGE REQUIREMENTS
FOR
VALLEY VIEW TRAILER VILLAGE
Thermal - Riverside County**

The California Regional Water Quality Control Board, Colorado River Basin Region, finds that:

1. Zivadin Babich, owner, 3158 Los Placitas, Las Cruces, New Mexico, 88001, has leased Valley View Trailer Village to Jose Rubio (hereinafter both are referred to as the discharger), P. O. Box 864, Thermal, California 92274, who verified on May 13, 1985 that the below updated information in Finding No. 2 is accurate.
2. The discharger is discharging a maximum of 8,000 gallons-per-day of domestic sewage from a mobile home park having 42 mobile home spaces. The wastewater is piped approximately 300 feet behind the park into a system of septic tanks that are pumped into two (2) oxidation basins for disposal by evaporation and infiltration. The disposal area is located in the NW $\frac{1}{4}$ of the NW $\frac{1}{4}$ of Section 23, T6S, R8E, SBB&M.
3. The disposal site is about one (1) mile east of the nearest sewer line on Avenue 56.
4. The discharge of this mobile home park has been subject to waste discharge requirements adopted in Board Order No. 78-25.
5. There are no domestic wells within 500 feet of the sewage disposal facilities described in Finding No. 2 (above).
6. The Water Quality Control Plan for the Colorado River Basin Region of California was adopted by the Regional Board on November 14, 1984. The Basin Plan contains water quality objectives for Coachella Hydrologic Subunit.
7. The beneficial uses of ground waters at the location of the waste discharge are:
 - a. Deep ground waters used for municipal supply, industrial supply and agricultural supply.
 - b. Shallow ground waters influenced by agricultural operations, are saline, and enter irrigation drains and flow to Salton Sea. Ground water depth at the site is about eight (8) feet.

*Superseded
09-19-90
by 90-062*

8. The Board has notified the discharger and interested agencies and persons of its intent to update waste discharge requirements for the discharge.
9. The Board in a public meeting heard and considered all comments pertaining to the discharge.
10. These waste discharge requirements govern an existing facility, which the discharger is currently operating, and therefore is exempt from the provisions of the California Environmental Quality Act in accordance with Section 15301 of Title 14, Chapter 3, of the California Administrative Code.

IT IS HEREBY ORDERED, the discharger shall comply with the following:

A. Discharge Specifications

1. Neither the treatment nor the discharge of wastewater shall create a pollution or a nuisance as defined in Division 7 of the California Water Code.
2. No wastewater other than domestic sewage shall be discharged into the sewage disposal system described in Finding No. 2 (above).
3. A minimum depth of freeboard of at least two (2) feet shall be maintained in each of the earthen basins.
4. Treated or untreated sludge, or similar solid waste, shall be disposed only at locations approved by the Regional Board.
5. Adequate measures shall be taken to assure that unauthorized persons and animal pets are effectively excluded from contact with the discharge.
6. Adequate measures shall be taken to assure that flood or surface drainage waters do not erode or otherwise render portions of the discharge facilities inoperable.
7. There shall be no surface flow of wastewater away from the discharge facilities.
8. There shall be no discharge, bypass, or flow of treated or untreated sewage to any channel which drains to the Salton Sea.
9. Septic tank cleanings shall be discharged only by a duly authorized service.
10. Treatment and disposal by ponding shall be conducted in such manner that there shall be no stranded or exposed sewage solids.
11. Treatment and discharge of wastewater shall be conducted by technical procedures which will maintain a surface aerobic environment.

12. Infiltration facilities shall be maintained and operated so as to maximize infiltration and minimize the increase in salinity of the infiltrating wastewater.
13. Standby facilities shall be provided in the event of pump and/or commercial power failure.

B. Provisions

1. Prior to any modifications in this facility which could result in material change in the quality or quantity of wastewater discharged, or any material change in location of discharge, the discharger shall report in writing to the Regional Board.
2. Upon request from this Board's Executive Officer, the discharger shall furnish technical and/or monitoring reports on the treatment and discharge of waste.
3. In the event of any change in control or ownership of land or waste disposal facilities owned or controlled by the discharger, the discharger shall:
 - a. Notify the Board of such change; and
 - b. Transmit a copy of this Order to the succeeding owner or operator, and file a copy of the transmittal letter with this Board.
4. This Order supersedes Board Order No. 78-25.

I, Arthur Swajian, Executive Officer, do hereby certify the foregoing is a full, true and correct copy of an Order adopted by the California Regional Water Quality Control Board, Colorado River Basin Region, on August 7, 1985.


Executive Officer

**CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
COLORADO RIVER BASIN REGION**

**MONITORING AND REPORTING PROGRAM NO. 85-69
FOR
VALLEY VIEW TRAILER VILLAGE
Thermal - Riverside County**

Location of Discharge: Portion of the NW $\frac{1}{4}$, NW $\frac{1}{4}$ of Section 23, T6S, R8E, SBB&M

MONITORING

The discharger shall submit the following information in an annual status report:

1. Estimate of average daily flow (gpd) of sewage discharged to basin(s).
2. Estimate of number of persons presently discharging to the sewerage system.
3. List of any proposed changes during the coming year.
4. Explain any problems in the sewerage system during the preceding year.

REPORTING

1. Monitoring reports shall be submitted to the Regional Board annually by January 15th of each year to:

California Regional Water Quality Control Board
Colorado River Basin Region
73-271 Highway 111, Suite 21
Palm Desert, CA 92260


2. Report immediately any failures of the sewage system by telephone and follow-up by letter.

ORDERED BY:


Executive Officer


Date

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD -7



Scale:
1"=2,000'

SITE MAP

VALLEY VIEW TRAILER VILLAGE
 Thermal - Riverside County
 NW¼, NW¼ of Section 23, T6S, R8E, SBB&M
 USGS Indio 7.5 min. Topographic Map

Order No. 85-69