

**CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD  
COLORADO RIVER BASIN REGION**

**ORDER NO. 86-74**

**WASTE DISCHARGE REQUIREMENTS  
FOR  
SILVER SPUR MOBILE MANOR  
South of Palm Desert - Riverside County**

The California Regional Water Quality Control Board, Colorado River Basin Region, finds that:

1. Silver Spur Reserve (hereinafter also referred to as the discharger), 50-001 Highway 74, Palm Desert, California, 92260, via the park manager, verified the below updated information on the discharge of waste on June 18, 1986.
2. The discharger is discharging a maximum of 50,000 gallons-per-day of domestic sewage from a mobile home and travel trailer park having 215 mobile home spaces, 36 travel trailer spaces, four (4) restrooms, two (2) laundry rooms, and a clubhouse. The wastewater is discharged into septic tank/seepage pit disposal systems located in the SW 1/4 of the SW 1/4 of Section 31, T5S, R6E, SBB&M.
3. The discharger is reserving areas of sufficient size for possible future 100 percent replacement of the seepage pits.
4. The discharge has been subject to waste discharge requirements contained in Board Order No. 76-48.
5. There are no domestic wells within 200 feet of the discharge facilities described in Findings No. 2 and 3 (above).
6. The discharger states that wastewater from a swimming pool and two (2) therapeutic pools is discharged onto landscape plantings.
7. The Water Quality Control Plan for the Colorado River Basin Region of California was adopted by the Regional Board on November 14, 1984.
8. The beneficial uses of ground water of the Coachella Hydrologic Subunit as stated in said Plan are:
  - a. Municipal supply
  - b. Industrial supply
  - c. Agricultural supply
9. The nearest sewer line is located adjacent to the park, and the discharger has agreed to connect all of the facilities should a failure occur in any of the septic tank/seepage pit disposal systems. A portion of the park has been connected to this sewer.

*Rescinded  
1/27/88 -  
by order  
88-17*

10. The Board has notified the discharger and interested agencies and persons of its intent to update waste discharge requirements for the discharge.
11. The Board in a public meeting heard and considered all comments pertaining to the discharge.
12. These waste discharge requirements govern an existing facility, which the discharger is currently operating, and therefore is exempt from the provisions of the California Environmental Quality Act in accordance with Section 15301 of Title 14, Chapter 3 of the California Administrative Code.

IT IS HEREBY ORDERED, the discharger shall comply with the following:

A. Discharge Specifications


1. Neither the treatment nor the discharge of wastewater shall create a pollution or a nuisance as defined in Division 7 of the California Water Code.
2. No wastewater other than domestic sewage and swimming and hot pool wastewater shall be discharged at this location.
3. Wastewater discharged subsurface shall be retained underground with no surfacing.
4. Adequate measures shall be taken to assure that flood or surface drainage waters do not erode or otherwise render portions of the discharge facilities inoperable.
5. Septic tank cleanings shall be discharged only by a duly authorized service.
6. Swimming pool and hot pool wastewater shall not be discharged into a sewage disposal system.

B. Provisions


1. Sufficient land area shall be reserved for possible future 100 percent replacement of the seepage pits, until such time as this park is connected to a municipal sewerage system.
2. Upon request from this Board's Executive Officer, the discharger shall furnish technical and/or monitoring reports on the treatment and discharge of wastes.
3. Prior to any modifications of this facility which would result in material change in the quality or quantity of wastewater discharged, or any material change in location of discharge, the discharger shall report in writing to the Regional Board.
4. Prior to any change of ownership of this mobile home and travel trailer park, the discharger shall:

- a. Specify as a condition of transfer that the area specified in Provision B.1 (above) remain servient to the park for the purpose of providing additional subsurface sewage disposal capacity, until such time as this park is connected to a municipal sewerage system.
  - b. Transmit a copy of this Order to the succeeding owner or operator, and file a copy of the transmittal letter with this Board.
5. This Order supersedes Board Order No. 76-48.

I, Arthur Swajian, Executive Officer, do hereby certify the foregoing is a full, true, and correct copy of an Order adopted by the California Regional Water Quality Control Board, Colorado River Basin Region, on September 17, 1986.

  
Executive Officer

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD - 7



Scale:  
1" = 1 mi.

**SITE MAP**

SILVER SPUR MOBILE MANOR  
South of Palm Desert - Riverside County  
SW 1/4, SW 1/4 of Section 31, T5S, R6E, SBB&M  
USGS Palm Desert 15 min. Topographic Map

Order No. 86-74

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD  
COLORADO RIVER BASIN REGION

MONITORING AND REPORTING PROGRAM NO. 86-74

FOR

SILVER SPUR MOBILE MANOR

South of Palm Desert - Riverside County

Location: Portion of the SW $\frac{1}{4}$  of the SW $\frac{1}{4}$  of Section 31, T5S, R6E, SBB&M

MONITORING

The discharger shall submit an annual status report on the following:

1. Number of spaces presently connected to the sewerage system.
2. List any proposed changes in the sewage disposal facilities during the upcoming year.

REPORTING

1. Annual reports are to be submitted by January 15th of each year to:

California Regional Water Quality Control Board  
Colorado River Basin Region  
73-271 Highway 111, Suite 21  
Palm Desert, CA 92260

2. Immediate reporting of any surfacing of wastewater or other failures of the system by telephone and follow-up by letter.

Ordered by:

Arthur Levajian  
Executive Officer

June 29, 1987  
Date