



**Power Plant Cooling
--What are the trade-offs?**

**John S. Maulbetsch
Maulbetsch Consulting
December 7, 2005**

Overview

- ✓ **Power plants use water**
- ✓ **Largest use is for condenser cooling**
- ✓ **Some cooling systems use less water than others**
- ✓ **Tradeoffs are**
 - **Amount of water used**
 - **Cost**
 - **Plant efficiency and output**

The conclusions- in advance

Water conserving cooling systems are available at a price


- ✓ **Increased capital cost---500 MW plants
0.4% to 12.5%**
- ✓ **Increased cooling system power
0.5 to 3.0 MW**
- ✓ **Increased plant heat rates
0.4 to 4.0 %**
- ✓ **Increased power production costs
1.9 to 4.9%**

Plants


Discussion limited to.....

- ✓ **Plants with condenser cooling**
 - **Combined-cycle plants**
 - **Steam plants**
 - **Not simple cycle turbines or reciprocating engines**
- ✓ **New plants**
 - **Not retrofits**

Combined Cycle Plant




Steam Plant




Cooling systems

- ✓ **Commonly used**
 - **Once-through**
 - **Wet cooling**
 - **Dry cooling**
- ✓ **Others**
 - **Hybrid (wet/dry) cooling**
 - **Spray enhanced dry cooling**

Once-through




Wet Cooling Tower





Air Cooled Condenser







Water source

- ✓ Natural
 - ✓ Ocean
 - ✓ Fresh surface water
 - ✓ Groundwater
 - potable
 - brackish
- ✓ Reclaimed
 - ✓ Municipal discharge
 - ✓ Agricultural run-off


Cooling Water Taken In—500 MW Combined Cycle Plant




Cooling Water Consumption---500 MW Combined Cycle Plants




Capital Cost—500 MW Combined Cycle Plant




Normalized Capital Cost---500 MW Combined Cycle




Design Heat Rate---500 MW Combined Cycle Plant




Hot Day Capacity Loss---500 MW Combined Cycle Plants (Includes Effect on Combustion Turbines)




Cooling Water Taken In---500 MW Steam Plant




Cooling Water Consumed---500 MW Steam Plant




Capital Cost---500 MW Steam Plant




Normalized Capital Cost---500 MW Steam Plant




Design Heat Rate---500 MW Steam Plant



Hot Day Heat Rate Increase—500 MW Steam Plants




Power for Cooling System Pumps and Fans




Maintenance Costs

- ✓ Labor, chemicals and equipment
- ✓ Highly site-specific
- ✓ Estimated at 1 to 3% of cooling system capital cost
- ✓ 10's to 100's of k\$ per year---negligible in comparison to other cost items

Levelized Cost Components for Sample Combined-Cycle Natural Gas Power Plant




Production Cost Breakdown---Dry Cooling 500 MW Combined-Cycle Plant



Cost of Electricity---500 MW Combined-Cycle Plant

■ Cost due to Capital ■ Cost due to fuel


Annualization factor--0.075; Cost of fuel--\$6/MMBtu; Capacity factor--8,100 hours/year



Cost of Electricity---500 MW Steam Plant

■ Cost due to Capital ■ Cost due to fuel


Annualization factor--0.075; Cost of fuel--\$6/MMBtu; Capacity factor--8,100 hours/year



Additional considerations

- ✓ Benefit of “a little bit” of water
 - Hybrid (wet/dry) systems
 - Spray enhancement

Hybrid (wet/dry) system




**Tucuman 450 MW Combined Cycle (Argentina)
PAC SYSTEM®
(Air Cooled Condenser & Wet Cooling System)**



Hybrid System Cost Estimate

Capital Cost of Cooling System



Spray enhancement

- ✓ Spray water into inlet air stream of air-cooled condenser
- ✓ Low capital cost approach
- ✓ Low annual water use
- ✓ Reduce inlet temperature by 5 to 10 F
- ✓ Restore “hot day” capacity loss



Summary— Combined-Cycle Plants

500 MW Combined-Cycle Plant				
Items for comparison	Cooling System			
	Once-through	Wet tower	Dry cooling	Hybrid
Plant Cost				
Capital, \$	198,800,000	201,200,000	223,700,000	Variable
Normalized Capital Cost, \$/kW	405.7	410.6	456.5	Variable
Performance				
Cooling System Power, kW	2,075	2,720	2,980	Variable
Design Heat Rate, Btu/kWh	6,549	6,573	2,980	Close to dry
Hot day Capacity Loss, MW	Base	2.7	26.1	Close to wet
Water				
Water taken in, gpm	132,410	2,290	0 (for cooling)	20 - 30% of wet
Water consumed, gpm	<i>De minimis ??</i>	2,048	0 (for cooling)	"

Summary— Steam Plants

500 MW Steam Plant				
Items for comparison	Cooling System			
	Once-through	Wet tower	Dry cooling	Hybrid
Plant Cost				
Capital, \$	302,900,000	304,200,000	341,300,000	Variable
Normalized Capital Cost, \$/kW	405.7	410.6	456.5	Variable
Performance				
Cooling System Power, kW	2,021	4,580	5,095	Variable
Design Heat Rate, Btu/kWh	7,800	8,088	8,129	Close to dry
Hot day Heat Rate, Btu/kWh	Base	0.48%	8.62%	Close to wet
Water				
Water taken in, gpm	180,500	3,680	0 (for cooling)	20 - 30% of wet
Water consumed, gpm	<i>De minimis ??</i>	2,940	0 (for cooling)	"